

Required Elements for Wet Extended Detention Ponds

Feasibility

Required Elements

- Stormwater ponds shall not be located within jurisdictional waters, including wetlands.
- Evaluate the site to determine the Hazard Class, and to determine what design elements are required to ensure dam safety (see *Guidelines for Design of Dams*). For the most recent copy of this document, contact the New York State Department of Environmental Conservation, Dam Safety Division, at: 518-402-8151.
- Avoid direction of hotspot runoff to design P-5 (Pocket Pond).
- Provide a 2' minimum separation between the pond bottom and groundwater in sole source aquifer recharge areas.

Conveyance

Inlet Protection

Required Elements

- A forebay shall be provided at each pond inflow point, unless an inflow point provides less than 10% of the total design storm flow to the pond.

Adequate Outfall Protection

Required Elements

- The channel immediately below a pond outfall shall be modified to prevent erosion and conform to natural dimensions in the shortest possible distance, typically by use of appropriately-sized riprap placed over filter cloth. Typical examples include submerged earthen berms, concrete weirs, and gabion baskets.
- A stilling basin or outlet protection shall be used to reduce flow velocities from the principal spillway to non-erosive velocities (3.5 to 5.0 fps). (See Appendix L for a table of erosive velocities for grass and soil).

Pretreatment

Required Elements

- A sediment forebay is important for maintenance and longevity of a stormwater treatment pond. Each pond shall have a sediment forebay or equivalent upstream pretreatment. The forebay shall consist of a separate cell, formed by an acceptable barrier. Typical examples include earthen berms, concrete weirs, and gabion baskets.
- The forebay shall be sized to contain 10% of the water quality volume (W_{QV}), and shall be four to six feet deep. The forebay storage volume counts toward the total W_{QV} requirement.
- The forebay shall be designed with non-erosive outlet conditions, given design exit velocities.
- Direct access for appropriate maintenance equipment shall be provided to the forebay.
- In sole source aquifers, 100% of the W_{QV} for stormwater runoff from designated hotspots shall be provided in pretreatment.

Treatment

Minimum Water Quality Volume (W_{QV})

Required Elements

- Provide water quality treatment storage to capture the computed W_{QV} from the contributing drainage area through a combination of permanent pool, extended detention (W_{QV-ED}) and marsh. The division of storage into permanent pool and extended detention is outlined in Table 6.1.

Table 6.1 Water Quality Volume Distribution in Pond Designs		
Design Variation	%WQ _v	
	Permanent Pool	Extended Detention
P-1	20% min.	80% max.
P-2	100%	0%
P-3	50% min.	50% max.
P-4	50% min.	50% max.
P-5	50% min.	50% max.

- Although both C_{PV} and W_{QV-ED} storage can be provided in the same practice, W_{QV} cannot be met by simply providing C_{PV} storage for the one-year storm.

Minimum Pond Geometry

Required Elements

- The minimum length to width ratio for the pond is 1.5:1 (i.e., length relative to width).
- Provide a minimum Surface Area:Drainage Area of 1:100.

Landscaping

Pond Benches

Required Elements

- The perimeter of all deep pool areas (four feet or greater in depth) shall be surrounded by two benches:
 - Except when pond side slopes are 4:1 (h:v) or flatter, provide a safety bench that generally extends 15 feet outward (10' to 12' allowable on sites with extreme space limitations) from the normal water edge to the toe of the pond side slope. The maximum slope of the safety bench shall be 6%; *and*
 - Incorporate an aquatic bench that generally extends up to 15 feet inward from the normal shoreline, has an irregular configuration, and a maximum depth of 18 inches below the normal pool water surface elevation.

Landscaping Plan

Required Elements

- A landscaping plan for a stormwater pond and its buffer shall be prepared to indicate how aquatic and terrestrial areas will be vegetatively stabilized and established.

Pond Buffers and Setbacks

Required Elements

- A pond buffer shall be provided that extends 25 feet outward from the maximum water surface elevation of the pond. The pond buffer shall be contiguous with other buffer areas that are required by existing regulations (e.g., stream buffers). An additional setback may be provided to permanent structures.

- Woody vegetation may not be planted or allowed to grow within 15 feet of the toe of the embankment and 25 feet from the principal spillway structure.

Maintenance

Required Elements

- Maintenance responsibility for a pond and its buffer shall be vested with a responsible authority by means of a legally binding and enforceable maintenance agreement that is executed as a condition of plan approval.
- The principal spillway shall be equipped with a removable trash rack, and generally accessible from dry land.
- Sediment removal in the forebay shall occur every five to six years or after 50% of total forebay capacity has been lost.

Maintenance Access

Required Elements

- A maintenance right of way or easement shall extend to the pond from a public or private road.

Non-clogging Low Flow Orifice

Required Elements

- A low flow orifice shall be provided, with the size for the orifice sufficient to ensure that no clogging shall occur. (See Appendix K for details of a low flow orifice and trash rack options).

Riser in Embankment

Required Elements

- The riser shall be located within the embankment for maintenance access, safety and aesthetics.

Pond Drain

Required Elements

- Except where local slopes prohibit this design, each pond shall have a drain pipe that can completely or partially drain the pond. The drain pipe shall have an elbow or protected intake within the pond to prevent sediment deposition, and a diameter capable of draining the pond within 24 hours.

Adjustable Gate Valve

Required Elements

- Both the W_{QV}-ED outlet and the pond drain shall be equipped with an adjustable gate valve (typically a handwheel activated knife gate valve). A gate valve is not required if the W_{QV} is discharged through a weir. Valves shall be located inside of the riser at a point where they (a) will not normally be inundated and (b) can be operated in a safe manner.

Safety Features

Required Elements

- Side slopes to the pond shall not exceed 3:1 (h:v), and shall terminate at a safety bench.
- The principal spillway opening shall not permit access by small children, and endwalls above pipe outfalls greater than 48 inches in diameter shall be fenced to prevent a hazard.

Figure 6.3 Wet Extended Detention Pond (P-3)

